

LAFORUCHE PARISH FIRE DISTRICT NO. 3


**HURRICANE IDA DAMAGE RESTORATION
PORT FOURCHON FIRE STATION NO. 12 RESTORATION
HURRICANE IDA RECOVERY NUMBER: HIR-PF12
FEMA DI-NUMBER: 1209208
PORT FOURCHON, LAFOURCHE PARISH, LOUISIANA**

ADDENDUM NO. 2

Date Issued: August 23, 2022

This Addendum No. 2 shall be part of the above referenced project.

Acknowledge receipt of this Addendum No. 2 by inserting its number in the space provided in the Louisiana Uniform Public Work Bid Form of the Request for Proposals. Failure to do so may subject the bidder to disqualification.


Kevan D. Keiser, P.E.
GIS Engineering, LLC.



LAFORUCHE PARISH FIRE DISTRICT NO. 3
HURRICANE IDA DAMAGE RESTORATION
PORT FOURCHON FIRE STATION NO. 12 RESTORATION
HURRICANE IDA RECOVERY NUMBER: HIR-PF12
FEMA DI-NUMBER: 1209208
PORT FOURCHON, LAFOURCHE PARISH, LOUISIANA

This Addendum is issued for the purpose of modifying, clarifying, or revising, as applicable, the specified items of the original Contract Documents. It is also issued for the purpose of adding, as applicable, the attached specified items to the original Contract Documents, or deleting, as applicable, the attached specified items from the original Contract Documents. The Addendum and attachments shall be construed as much a part of the original Contract Documents as contained therein. Changes made by Addenda shall take precedence over original Contract Documents.

PART I – MODIFICATIONS TO CONTRACT DOCUMENTS TECHNICAL SPECIFICATIONS, PLANS, AND OTHER DOCUMENTS

Modifications to Contract Documents and Specifications.

PART II – ATTACHMENTS

1. Section 10 44 00 – Fire Protection Specialties (Revised as Per Addendum No. 2)

PART I – Modifications to Contract Documents, Technical Specifications, Plans, and Other Documents

Contract Documents:

NONE

Technical Specifications:

1. Section 10 44 00 – Fire Protection Specialties
 - a. Please revise paragraph 2.1 “Manufacturers” to read as follows:
Provide a fire alarm system manufactured by Engineering Systems Technology (EST), or approved equal in advance by Addendum.
 - b. Please revise paragraph 2.2 “Monitoring” to read as follows:
Provide fire alarm system that is ADT® Monitored, or approved equal in advance by Addendum.
 - c. Please revise the payment table in paragraph 4.2 “Payment” to read as follows:

Item No.	Pay Items	Pay Units
RS-04	Remove and Replace Alarm Bell	Each
E-11	Remove and Replace Smoke Detectors	Each
E-12	Remove and Replace Fire Alarm System	Each

Plans:

NONE

PART II - ATTACHMENTS

Section 10 44 00 – Fire Protection Specialties

SECTION 10 44 00
FIRE PROTECTION SPECIALTIES

PART 1 GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 DESCRIPTION OF WORK

- A. This work consists of the furnishing and installation of fire pull station, alarm light, and sprinklers in these specifications and conforming to the lines shown on the plans or established by the engineer.

1.3 REFERENCES

- A. NFPA 72 Smoke and Fire Alarms

1.4 SUBMITTALS

- A. Submit brochure and product data to Engineer.

1.5 QUALITY ASSURANCE

- A. Conform to NFPA 72 requirements for Smoke and Fire Alarms.
- B. Provide fire alarm system(s) by a single manufacturer.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Provide a fire alarm system manufactured by Engineering System Technology (EST), or approved equal in advance by Addendum.

2.2 MONITORING

- A. The fire alarm system shall be monitored by ADT®, or approved equal in advance by Addendum.

PART 3 EXECUTION

3.1 INSTALLATION

- A. Install items included in this section in locations and at mounting heights indicated, or if not indicated, at heights to comply with applicable regulations of governing authorities.
- B. Securely fasten mounting brackets to structure, square and plumb, to comply with manufacturer's instructions.

PART 4 MEASUREMENT AND PAYMENT

4.1 MEASUREMENT

- A. The contract unit price per for Fire Alarm Systems shall include furnishing all labor, materials, tools, equipment and any incidental items required to complete the work required by the plans and as specified.

4.2 PAYMENT

- A. Payment for the items listed below shall include all materials, equipment, labor and incidentals necessary to complete the work as shown on the drawings, and shall be paid under:

Item No.	Pay Items	Pay Units
RS-04	Remove and Replace Alarm Bell	Each
E-11	Remove and Replace Smoke Detectors	Each
E-12	Remove and Replace Fire Alarm System	Each

END OF SECTION 10 44 00